



155 South 750 West, North Salt Lake, Utah 84054
Phone 801-295-2341 - Fax 801-295-2656 - www.gramoll.com

Notice of Addendum

Addendum #2 Ivy Acres Park

This addendum includes specific changes and clarifications to the bid documents for the Ivy Acres Park New Park project.

- Item 2.1** Sub bids request date has been extended to June 13th at 2:00 PM
- Item 2.2** There is a potential for dewatering of the site.
- Item 2.3** In Section 32 13 60 Pickleball Court Surfacing- Part 2- Products
-References to “Players Choice” in specifications will be removed.
- Item 2.4** “Please ask the architect/owner what they want us to propose on for the following accessories as they are shown on the plans but not listed in the specifications. I have attached what we intend to bid if we get no response. - Toilet Paper Dispenser - Sanitary Napkin Disposal - Soap Dispenser - Paper Towel Dispenser - Hand Dryer”
-Farmington City will furnish and install Soap Dispensers. Contractor to furnish and install Toilet Paper Dispenser, Sanitary Napkin Disposal, and Hand Dryer. Items are to be stainless steel. Paper Towel Dispensers will be removed from the project. Clarification on Musco Sports Lighting
- Item 2.5** **Clarification on Musco Sports Lighting**
-City to purchase Musco Lighting and have it delivered to the contractor staging area. Misc smaller items can be stored at city facilities. Contractor to install Musco Sports Lighting and all required infrastructure.
- Item 2.6** **Substitutions:**
Ninja Warrior Course – Open to alternatives to Great Western Recreation layout?
-Yes, however it have timing and 40 yd dash to be considered “equal”

-Can TeKleen filter be substituted for Amiad Filter?
-No

Are Meyko site recreation products an approved equal vendor?
-No
- Item 2.7** **Are cut/fill calculations accurate?**
-Fill quantities are currently estimated to approximate finished grade. Updated quantities will be provided.
- Item 2.8** **Clarification for Pollinator kit addendum**
– Remove from bid



155 South 750 West, North Salt Lake, Utah 84054

Phone 801-295-2341 - Fax 801-295-2656 - www.gramoll.com

- Item 2.9 Supplier supplemental information**
 - Permatrak document “2023-2146_IN-A_For Bidding_06-03-2024” uploaded onto SciQuest for additional technical information regarding Permatrak installation.

- Item 2.10 On the planting plans it calls for biomeadow seed. In the spec it calls for biomeadow sod. Is it supposed to be seed or sod?**
 - It will be per the Basis of Bid, which calls for sod.